



POINT	REMARK	LEVELS
G	GUTTER INVERT	DRIVEWAY CROSSING SET-OUT POINT
L	REAR OF LAYBACK	100mm ABOVE GUTTER INVERT (MAY BE ALTERED AT COUNCIL'S DISCRETION)
B	1800mm FROM GUTTER INVERT	175mm ABOVE GUTTER INVERT TO TOP OF FORMWORK.
C	3500mm FROM GUTTER INVERT	FINISHED LEVEL TO BE 15mm BELOW FORMWORK BY USE OF AN 800mm EASE CENTRALISED ABOUT POINT B
A	BOUNDARY ALIGNMENT	85mm ABOVE GUTTER INVERT TO THE TOP OF FORMWORK.
T	1500mm BEFORE PARKING FACILITY	FINISHED LEVEL TO BE 40mm BELOW FORMWORK BY USE OF AN 800mm EASE CENTRALISED ABOUT POINT C
P	PARKING FACILITY	PLACE 10mm EXPANSION JOINT, CONTINUE CROSSING GRADIENT BETWEEN POINTS C AND T PROVIDE TRANSITIONAL SLOPE 1V:10H OVER 1500mm WHICH MAY BE PARTIALLY OR WHOLLY ON ROAD RESERVE MAXIMUM GRADE PARALLEL TO ANGLE OF PARKING 1V:20H FOR ANY OTHER DIRECTION 1V:16H

CONCRETE DRIVEWAY NOTES

1. LAYBACK AND GUTTER SHALL BE CONSTRUCTED IN PLAIN CONCRETE AND FINISHED WITH A STEEL TROWEL.
2. THE MINIMUM COMPRESSIVE STRENGTH FOR DRIVEWAYS SHALL BE 25MPa AT 28 DAYS. FOR COMMERCIAL OR INDUSTRIAL DRIVEWAYS THE SLAB DEPTH SHALL BE INCREASED TO MINIMUM OF 180mm WITH SLB2 STEEL MESH AND TOP COVER OF 30mm.
3. THE SUBGRADE SHALL BE EVENLY COMPACTED USING A VIBRATORY COMPACTION EQUIPMENT UNTIL IT SHOWS NO SIGNS OF MOVEMENT, OR AS DIRECTED BY COUNCIL.
4. ALL VEHICLE CROSSINGS SHALL BE CONSTRUCTED IN ACCORDANCE WITH LEVELS AND SPECIFICATION ISSUED BY COUNCIL AND MUST COMPLY WITH AS/NZS 2890:1:2004 "OFF STREET CAR PARKING" CODE.
5. ALL KERBSING SHALL BE CONSTRUCTED IN ACCORDANCE WITH STANDARD DRAWINGS AND SPECIFICATION ISSUED BY COUNCIL.
6. WHERE COUNCIL OR ITS REPRESENTATIVE DIRECTS THAT THE GUTTER IS TO BE RETAINED, THE CONTRACTOR IS TO PLACE A 75mm DEEP SAW CUT IN THE GUTTER INVERT AND REMOVE THE KERB AND/OR LAYBACK.
7. WHERE COUNCIL OR ITS REPRESENTATIVE DIRECTS THAT THE GUTTER IS TO BE DETAINED BEHIND TO COMMENCEMENT OF WORKS, THE GUTTER IS TO BE DETAINED BEHIND TO COMMENCEMENT OF WORKS.
8. THE CONSTRUCTION OF ALL VEHICLE CROSSINGS AND ASSOCIATED WORKS MUST BE PERFORMED BY A COUNCIL APPROVED CONTRACTOR.
9. SAWCUT 500mm ASPHALT STRIP AND MATCH IN LAYBACK WITH ROAD SURFACE TO SMOOTH TRANSITION.

VEHICLE CROSSING CONSTRUCTION NOTES

1. AT LEAST 48 HOURS' NOTICE OF INTENTION SHALL BE GIVEN TO COUNCIL ENGINEER TO POUR CONCRETE WITHIN THE ROAD RESERVE AND NO CONCRETE SHALL BE POURED UNTIL THE WORK HAS BEEN APPROVED AND AN INSPECTION NOTICE ISSUED.
2. ALL CONCRETE SLABS OF THE FOOTPATH, THE ADJOINING ROAD AND FINISHED LEVEL WITH THE CONCRETE SURFACE RAISED EDGES ARE UNACCEPTABLE.
3. THE ROAD ADJOINING THE VEHICLE CROSSING SHALL BE BATTERED AND TURFED AT A MAXIMUM GRADIENT OF 1V:6H OR AS DIRECTED BY COUNCIL.
4. CONCRETE FOOTPATH ADJUSTMENTS SHALL BE IN ACCORDANCE WITH COUNCIL'S SPECIFICATION AND SATISFACTION.
5. THE SUBGRADE MUST BE THOROUGHLY COMPACTED BY THE USE OF VIBRATORY COMPACTION EQUIPMENT UNTIL IT SHOWS NO SIGNS OF MOVEMENT, OR AS DIRECTED BY COUNCIL.
6. CONCRETE CROSSING SLABS MUST BE POURED IN PLAIN CONCRETE. SLAB SURFACE MUST BE COVE FINISHED (OR EQUIVALENT) AND EDGES TO BE FINISHED WITH A 50mm MARGIN.
7. ALL CHANGES IN GRADE SHALL BE SCHEDULED TO ENSURE NO RIGID/SHARP TRANSITIONS.
8. THE MINIMUM COMPRESSIVE STRENGTH OF CONCRETE SHALL BE AS FOLLOWS:
9. SINGLE RESIDENTIAL DWELLING: 130mm THICK REINFORCED WITH SL72 MESH PLACED 30mm BELOW TOP OF CONCRETE SLAB
- (g) MULTI-UNIT RESIDENTIAL: 150mm THICK REINFORCED WITH SL72 MESH PLACED 30mm BELOW TOP OF CONCRETE SLAB
- (g) COMMERCIAL OR INDUSTRIAL: 180mm THICK REINFORCED WITH SLB2 MESH PLACED 30mm BELOW TOP OF CONCRETE SLAB
10. THE VEHICLE CROSSING UP TO 2400mm FROM THE GUTTER INVERT SHALL BE GRADED PARALLEL TO THE ROAD CENTRELINE.
11. THE VEHICLE CROSSING SHALL BE CONSTRUCTED PERPENDICULAR TO THE ROAD PAVEMENT UNLESS OTHERWISE INSTRUCTED BY COUNCIL.
12. THE CONSTRUCTION OF ALL VEHICLE CROSSINGS AND ASSOCIATED WORKS ON THE ROAD RESERVE MUST BE COMPLETED BY A COUNCIL APPROVED CONTRACTOR.
13. ANY TREE ROOTS GREATER THAN 50mm IN DIAMETER ARE TO BE REMOVED UNLESS AUTHORISED BY A QUALIFIED ARBORIST.
14. ANY ROOTS APPROVED FOR REMOVAL SHALL BE CLEAN CUT WITH SHARP TOOLS SUCH AS SECAUTURS, PRUNERS, HANDSAWS, CHAINSAWS OR SPECIALISED ROOT PRUNING EQUIPMENT.

IMPORTANT DRIVEWAY DESIGN NOTES:

1. THE STANDARD DRIVEWAY PROFILES SHOWN MAY NOT SUIT ALL TERRAIN CONDITIONS.
2. THESE STANDARD DRIVEWAY PROFILES MAY NEED TO BE MODIFIED TO SUIT.
3. THE STANDARD DRIVEWAY PROFILES SHOWN MAY NOT TAKE INTO CONSIDERATION CONNECTING FOOTPATHS WHERE THE FOOTPATH MEETS THE DRIVEWAY FOR DRIVERS AND PASSENGERS TO CROSS. THE DRIVEWAY CROSS-FALL GRADIENT TOWARDS THE KERB OR ROAD SIDE. ALSO THE STANDARD DRIVEWAY PROFILES SHOWN HAS NOT BEEN DESIGNED TO ACCOMMODATE ANY SPECIAL NEEDS, FOR EXAMPLE, IN A FLOOD PLANNING AREA WHERE A MINIMUM FREE BOARD CREST IS REQUIRED TO PROTECT THE PARKING FACILITY.
4. WHERE MODIFICATION OF THE DRIVEWAY IS REQUIRED TO MEET EXISTING OR PROPOSED CROSS FALLS OR LEVELS, THE FINAL DESIGN PROFILE MUST BE CHECKED AGAINST THE AUSTRALIAN STANDARD AS/NZS 2890:1:2004 "OFF STREET CAR PARKING" CODE FOR SCRAPING AND BOTTOMING USING THE 85th PERCENTILE PASSENGER VEHICLE.
5. THE DESIGNER WILL NEED TO LIAISE WITH COUNCIL TO DEVELOP A SUITABLE DESIGN SOLUTION.

NO	DATE	INITIALS	AMENDMENTS
1	18/08/24	JM	INITIAL DRAWINGS

DESIGN DATE: 07/07/2022	DESIGN APPROVED BY: THOMAS LAU	APPROVED FOR CONSTRUCTION DATE: 20/07/24
DESIGNED BY: THOMAS LAU	APPROVED BY: E. HANSEN	PRINCIPAL ENGINEER

LEAD DESIGNER AND CO-ORDINATOR: THOMAS LAU	PROJECT MANAGER: THOMAS LAU
WORK-AS-EXECUTED BY: N.A.	DATE: 20/07/24
DATE: 20/07/24	DATE: 20/07/24

SCALE: 1:100	SCALE: 1:100
SCALE: 1:100	SCALE: 1:100

STANDARD DRAWINGS
DRIVEWAY PROFILE - EXTRA LOW (EL)

DRAWING NO. 1

